



# Certificate of Compliance

**Certificate:** LR 21451-75 (LR 21451-75)

**Master Contract:** 166730

**Project:** 2068676

**Date Issued:** 2008/08/11

**Issued to:** IDEC Corporation  
7-31 Nishimiyahara 1-chome  
Yodogawa-Ku, Osaka 532-8550  
Japan

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'*



**Issued by:** John Lam

A handwritten signature in black ink, appearing to be 'John Lam'.

**Authorized by:** Nick Alfano, Operations Manager

A handwritten signature in black ink, appearing to be 'Nick Alfano'.

## **PRODUCTS**

**CLASS 3211 03** - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Auxiliary Devices

Mono-lever switches, open type, Series ARN, ARNS and ARNL, maximum pilot duty rating: 600V ac, A600 (heavy duty), 600V dc, P600 (standard duty).

Notes



CSA INTERNATIONAL

**Certificate:** LR 21451-75 (LR 21451-75)

**Master Contract:** 166730

**Project:** 2068676

**Date Issued:** 2008/08/11

---

- The catalogue designations of the above units consists of series designation, may be prefixed by 2 or 3 letters and suffixes by 3 number or 3 numbers and a letter denoting number of contact blocks, type of operator head, transformer rating where applicable, number and arrangement of the contacts, etc.
- Operator and contact block may ship separately
- Open type devices are Certified as Components for use only in other Certified equipment where the suitability of the combination is to be determined by the CSA International.

#### **APPLICABLE REQUIREMENTS**

CSA C22.2 No. 14 - Industrial Control Equipment

#### **MARKINGS**