



# Certificate of Compliance

**Certificate:** 1902602 (LR 83454)

**Master Contract:** 166730

**Project:** 70013787

**Date Issued:** December 18, 2014

**Issued to:** IDEC Corporation  
6-64 Nishimiyahara 2-Chome  
Yodogawa-Ku, Osaka 532-0004  
Japan

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicator*



*Zhibin Li*

**Issued by:** Zhibin Li

## **PRODUCTS**

**CLASS 3215 30** - SUPPLEMENTARY PROTECTORS - COMPONENT ACCEPTANCE PROGRAM

Supplementary Protectors, Overcurrent Type, Cat. No. NC1V, followed by -1, -2, or -3, followed by 1, followed by 00, 11, 21, 12, 13, 22, 23, 31, 32 or 33 may be followed by F, may be followed by -0.1A to -30A, may be followed by S, A or M. 250Vac max. 125Vdc max. 0.1 to 30A, 50/60Hz.

Supplementary Protectors, Shunt Protector, Voltage type, Cat. No. NC1V, followed by -1, -2, or -3, followed by 5, followed by 00, followed by -DC24V. 250Vac max. 125Vdc max. 0.1 to 30A, 50/60 Hz. Coil voltage 24 to 48 Vdc.

## **APPLICABLE REQUIREMENTS**

CSA Standard C22.2 No. 235 - Supplementary Protectors