



# Certificate of Compliance

**Certificate:** 1206502 (LR 83454-2)

**Master Contract:** 166730

**Project:** 1617232

**Date Issued:** February 3, 2005

**Issued to:** Idec Izumi Corporation  
7-31 Nishimiyahara 1-chome  
Yodogawa-Ku, Osaka 532-8550  
Japan

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicator*



**Issued by:** R. Tateishi, P. Eng.

**Authorized** Nick Alfano, Operations Manager  
**by:**

A handwritten signature in black ink, appearing to read 'N. Alfano'.

## **PRODUCTS**

**CLASS 3215 30** - SUPPLEMENTARY PROTECTORS - COMPONENT ACCEPTANCE PROGRAM

Appliance component protectors, manual reset, magnetically operated, trip free mechanism, Type NRF Series, single-pole, overcurrent type rated 0.3A to 15A, 250V ac (50/60Hz), 32V dc, may be provided with auxiliary contacts rated 0.05A, 125V ac.

## **APPLICABLE REQUIREMENTS**

CSA Standard C22.2 No. 235 - Supplementary Protectors